



Part #	Volume (L,GAL)	NOMINAL STEEL THK.
30910053SCAA-07	9176, 2018	3.56 mm

NOTES:
 1. AIR / SOAP TEST TO 35 KPa (5 PSI) MAX.
 2. INTERIOR FINISH: CLEAN OF DEBRIS ETC.
 3. EXTERIOR FINISH: PHOSPHATE CLEAN AND APPLY 0.0035" to 0.0070" of WHITE POLYURETHANE 751 (PE0060ET AND PE0061ET)

Ce dessin est la propriété exclusive de Industries Granby, SEC. Aucune partie de ce dessin ne peut être utilisée ou reproduite sans sa permission écrite. This drawing is the exclusive property of Granby Industries LP. No part of this drawing may be used or reproduced in any manner without its written permission.			
TOLÉRANCES LINÉAIRES, LINEAR STD TOLERANCES 0 OR FRAC. (X/X) -> ±0.5" 0.00 -> ±0.125" 0.0 -> ±0.25" 0.000 -> ±0.0625"		Description de la révision / Revision description	
TOLÉRANCES ANGULAIRES, ANGULAR STD TOLERANCES 0 -> ± 2 DEG 0.0 -> ± 0.1 DEG. 0.0 -> ± 0.5 DEG.		Dessiné par / Drawn by S. Potvin	29/01/2018
Les soudures doivent respecter la spécification SI-0039. Tank welds must respect SI-0039 specifications.		Approuvé par / Approved by :	
Poids Approx. / Approx. Weight 2059 Lb / 934 Kg	Unités / Units INCHES	Echelle / Scale	Feuille / Sheet 1 / 1
		Industries Granby S.E.C., Granby Industries L.P. © 2017 Industries Granby, SEC. Granby Industries LP Format / Size No de la pièce / Part no. REV B Light_Ind_601HZ_2000gl 01	
		Description / Title RÉSERVOIR INDUSTRIEL LÉGER SUR BERCEAUX D/P - ULC-S601 - D/W LIGHT INDUSTRIAL TANK ON SUPPORTS	