

INSTALLATION AND MAINTENANCE GUIDELINES FOR TANK ASSEMBLIES FOR THE COLLECTION, STORAGE AND REMOVAL OF USED OIL

MODELS: • CYLINDRICAL CAN/ULC-S652 TANKS



Manufactured by :

Granby Industries L.P.
98, rue des Industries, Cowansville, Quebec
J2K 0A1, Canada
Telephone: 450-378-2334
Fax: 450-378-5202

E-mail: service@granbyindustries.com
Website: <http://www.granbyindustries.com>

1. Scope

These instructions apply to cylindrical CAN/ULC-S652 tanks manufactured by Granby Industries. These tanks are designed for the storage of flammable (*any liquid having a closed cup flash point below 37.8°C and a vapour pressure not exceeding 276 kPa (absolute) at 37.8°C*) and combustible (*any liquid having a closed cup flash point at or above 37.8°C and below 93.3°C*) liquids with a relative density not greater than 1.0.

These "non-pressure" type tanks are intended be normally vented to atmosphere and are not intended to accommodate internal pressures at the top of the tank exceeding 7 kPa (1 psi) gauge nor internal vacuum greater than 300 Pa (0.044 psi) gauge.

The tank installer shall consult with the authority having jurisdiction that the requirements of CAN/ULC-S652:2016-REV1 Standard and all Federal, Provincial, and Local Codes are met prior to installation.

2. Tank Inspection

Inspect the tank immediately upon receipt. Minor dents and scratches may be acceptable and repaired on site. If damages affect the integrity and performance of the tank, please contact your distributor.

3. Tank Lifting & Handling

The tank is to be lifted by means of the lifting lug(s) provided on the top of the tank. Do not drop or use the used oil tank to transport any product or move the tank unless it is empty.

4. Tank Installation

4.1. Location of Tank

The tank should be located at a safe distance from property lines, public ways, important buildings and adjacent tanks. Refer to applicable codes and local authorities.

If possible, the tank should rest on a foundation of concrete, masonry, piling or steel. This foundation should be designed to minimize the uneven settling of the tank and to minimize the corrosion of the components resting on the foundation. The site should have all organic materials such as sod or bark removed and the soil should be mechanically compacted. A well-drained sub grade should then be utilized to provide appropriate drainage.

Clearances below the tank shall prevent any part of the tank, except for its base, to be in contact with the soil or foundation.

4.2. Tank Piping

Before beginning the piping or the installation of accessories, remove shipping caps from each flange.

4.2.1. Tank Vent

Each tank is vented in accordance with CAN/ULC-S602:2014-REV1 and CAN/ULC-S652:2016-REV1 Standards to prevent the build-up of pressure or vacuum inside the tank when filling, emptying or when subjected to atmospheric temperature changes.

4.2.2. Openings Below Liquid Level

Each opening below liquid level through which liquid does not normally flow shall be plugged with a liquid tight closure.

4.2.3. Openings Above Liquid Level

All openings that remain unused after completion of the installation should be properly sealed with a liquid tight metal threaded pipe plug.

5. Oil Tank Management (Maintenance)

- Each tank should be inspected and maintained to ensure compliance with the requirements of the codes regulating it;
- The tank and all tank accessories should be maintained to ensure that they function as intended;
- If a tank is found to be leaking, it should be emptied of its contents immediately and be replaced;
- The tank should be inspected at least once a year for the presence of water. Any water found shall be removed immediately;
- All openings on the tank that are not in use should be plugged or sealed in accordance with 4.2.2 or 4.2.3 above; and
- If the foundation is not stable or the tank is likely to topple; take immediate remedial action to correct the situation.